



Date: April 18, 2024

Deputy Chief Brian McCrae
NYS Division of Homeland Security and Emergency Services
Office of Fire Prevention and Control
State Office Campus, Building 7A-Floor 2
1220 Washington Avenue
Albany, NY 12226

Deputy Chief McCrae:

SUNY Canton is requesting a time extension for 5 Fire Safety violations. The issue was identified during our annual campus fire safety inspection conducted by Fire Protection Specialist Victoria Charland and SUNY Canton Representatives on April 11, 2024.

The justification for this extension and the extension request date is listed on the attached spreadsheet.

If you would like to discuss this time extension request, I can be reached at (315) 379-3820.

Thank you for your time and consideration on this matter.
Regards,

A handwritten signature in blue ink that reads "Shawn K. Miller".

Shawn K. Miller
VP for Administration
Chief Financial Officer
SUNY Canton College of Technology

Attachments (1)

**SUNY CANTON COMPLIANCE PLAN
for 2024 OFPC FIRE SAFETY INSPECTIONS**

DATE: 4/17/24

State Fire ID:	Building	Violation #	Compliance Description	Extension Date Requested
16793	CARC	50	SUNY Canton will fully replace the double set of Fire Doors to comply with the closing and latching requirements of the 2020 NYS FC_705.2.4	8/31/24
712	Chaney Dining Hall	64	SUNY Canton will either replace the electrical panels or covers/doors to comply with 2020 NYSFC-604.1 to provide panel doors that close and latch.	8/31/24
706	Cook Hall	47	SUNY Canton will either replace the electrical panels or covers/doors to comply with 2020 NYSFC-604.1 to provide panel doors that close and latch.	8/31/24
706	Cook Hall	48	SUNY Canton will either replace the electrical panels or covers/doors to comply with 2020 NYSFC-604.1 to provide panel doors that close and latch.	8/31/24
711	Southworth Library	40	SUNY Canton will either replace the electrical panels or covers/doors to comply with 2020 NYSFC-604.1 to provide panel doors that close and latch.	8/31/24